

**UNI7.S711
Boxes, Noncoded Certified for Canada**[Page Bottom](#)**Boxes, Noncoded Certified for Canada**[See General Information for Boxes, Noncoded Certified for Canada](#)**FIRE-LITE ALARMS**

S711

1 Fire-lite PI

Northford, CT 06472 USA

Models BG-12, -12L, -12LA, -12LPS, -12LPSP, -12LR, -12LRA, -12LSP, -12LX, -12NC, -12PS, -12S, -12SP.

Models BG-12LAO, -12LAOB, -12LO, -12LOB, -12LW, -12LWP, -12W, -12WP are for outdoor use when used with a back box as specified in the installation instruction.

Model BG-12LXSP.

Model UT-PS2.

Back box, Model BG-12SL.

Model BG-8, Input: 24-30 V dc, 1.0 A; Model BG-10, Input: 24-30 V dc, 3.0 A.

Manual Pull Stations, Conventional Models FL-MPS-SC, FL-MPS-SCB, FL-MPS-SCC, FL-MPS-2C, FL-MPS-2CC, rated 10 A, 120 V ac.

Model	Stage Type	Switch	Colour	Action
FL-MPS-SC	Single	N.O.	Red	Single
FL-MPS-SCB	Single	N.O.	Blue	Single
FL-MPS-SCC	Single	N.O. & N.C.	Red	Dual
FL-MPS-2C	Two	N.O. & Key Switch	Red	Single
FL-MPS-2CC	Two	N.O., N.C. & Key Switch	Red	Dual

Manual pull stations, Addressable Models FI-MPS-SA, FI-MPS-SAC, rated 24 VDC, 550uA. Models FI-MPS-2A, FI-MPS-2AC, rated 24 VDC, 1100uA.

Model	Stage Type	Switch	Colour	Action
FI-MPS-SA	Single	N.O.	Red	Single
FI-MPS-SAC	Single	N.O. & N.C.	Red	Dual
FI-MPS-2A	Two	N.O. & Key Switch	Red	Single
FI-MPS-2AC	Two	N.O., N.C., & Key Switch	Red	Dual

[Last Updated](#) on 2016-05-26[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

Copyright © 2018 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and

covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2018 Underwriters Laboratories of Canada Inc."