

**UOXX7.S2424****Control Unit Accessories, System Certified for Canada**[Page Bottom](#)**Control Unit Accessories, System Certified for Canada**[See General Information for Control Unit Accessories, System Certified for Canada](#)**FIRE-LITE ALARMS**

S2424

1 Fire-lite PI

Northford, CT 06472 USA

Amplifier - subassembly, for use with Fire-Lite Emergency Command Center-ACU, Model ECC-50/100 Model(s) ECC-50W-25V, ECC-50W-70V**Backboxes** Model(s) ANN-SB80KIT-B(f15), ANN-SB80KIT-R(f15), ANN-SB80KIT-W(f15)**Battery chargers, input 120 V, 60 Hz, 2.0 A, for use with ULC listed control unit MS-9600** Model(s) CHG-120F**Class A converter modules, for use with Fire-Lite circuit extender Models FCPS-24FS6C and FCPS-24FS8C** Model(s) ZNAC-4**Control modules** Model(s) CMF-300 (f20), CRF-300 (f20)**Control modules, 15-32 V dc, 6.5 mA maximum, compatible for connection only on the intelligent communication circuit of Models AMS-9200 and MS-9200 fire alarm control units by Fire-Lite Alarms** Model(s) CMF-300A**Control modules, 24 V dc, 1.0 A** Model(s) C304A**Emergency command center - ACU, input 120 V ac, 60 Hz, 3.5 A** Model(s) ECC-50/100**Enclosures** Model(s) ROME**Fault isolator modules, , 24 V dc, 410 uA, for connection only on the intelligent communication circuit of Model MS9200 fire alarm system control unit by Fire-Lite Alarms, Inc.** Model(s) C304A, I300A**Input/output modules, 15-32 Vdc, 24 mA** Model(s) CDRM-300A**Input/output relay modules, 15-32 Vdc, 2.0 mA** Model(s) IO900**Local Operator Console** Model(s) ECC-LOC (f20)**Local operator consoles, input 24 V dc, 85 mA** Model(s) ECC-LOC**Main power supplies, 120 V, 60 Hz, 1.25 A** Model(s) MPS-24**Mini monitor modules, 15-32 V dc, 375 mA maximum** Model(s) MMF-301A**Miniature monitor modules, 24 V dc, 230 uA** Model(s) M301A**Monitor modules** Model(s) M300A, M302A**Monitor modules, 15-32 V dc, 5.1 mA maximum** Model(s) MMF-300A, MMF-302A**Monitor modules 15-32 V dc, 5.7 mA, compatible for connection only on the intelligent communication circuit of Model AFC600 fire alarm system control unit by Notifier, either in Flashscan or CLIP mode** Model(s) MDF-300**Multi-monitor module, system sensors, rating 15-32 V dc, 60 mA per circuit** Model(s) MMF-300-10A**Multi-monitor modules, rating: 15-32 V dc, 60 mA** Model(s) MMF-300-10A**Multi-relay six control module, system sensors, rating: 15-32 V dc alarm and rating for relay contact 18-28 V dc, 3 A max or 125 V ac @ 0.5A** Model(s) CRF-300-6A**Multi-relay-Six-control modules, rating 15-32 V dc alarm and rating for relay contact 18-28 V dc, 3 A max or 125 V ac @ 0.5 A** Model(s) CRF-300-6A**Multi-supervised control module, system sensors, input 15-31 V dc, 35 mA @ alarm, output 18-28 V dc, 3 A, 63 W @ 70.7**

V ac per circuit and 22.5W @ 25 V ac per circuit Model(s) CMF-300-6A

Multi-supervised control modules, input 15-31 V dc, mA @ Alarm, Output 18-28 V dc, 3 A, 63 W @ 70.7 V ac per circuit and 22.5 W @ 25 V ac Model(s) CMF-300-6A

Notification appliance circuit extenders, input 120 V, 60 Hz, 3.2 A Model(s) FCPS-24FS6C, FCPS-24FS8C

Power supply/field chargers, 120 V, 60 Hz, 2.0 A Model(s) FCPS-24F

Printer Model(s) PRN-6F

Relay control modules, 15-24 V dc, 5.2 mA max at 15 V dc on alarm Model(s) MDF-300A

Relay control modules, 15-32 V dc, 6.5 mA maximum, compatible for connection only on the intelligent communication circuit of Models AMS-9200 and MS-9200 fire alarm control units by Fire-Lite Alarms Model(s) CRF-300A

Relay modules, input 24 V dc, 75 mA, individual relay contacts rated 30 Vac, 0.5 A resistive, 30 V dc, 2 A resistive Model(s) ANN-RLY(f13)

Remote annunciators Model(s) ANN-100

Remote annunciators, input 18-28V dc, 68mA Model(s) ANN-LED(f13)

Remote annunciators, input 24 V dc, 56 mA Model(s) ACM-16ATCS4F, ACM-16ATYF

Remote annunciators, input 24VDC, 200mA Model(s) ANN-I/O, intended for use with specific control units as indicated in control unit installation manual.

Remote control relay modules, input 24 V dc, 158 mA Model(s) ACM-8RF

Remote Indicator - subassembly Model(s) ULC-Replacement Parts: LCD-80FC

Serial/parallel interfaces Model(s) ANN-S/PG

Six zone interface module, system sensors, rating 15-32 V dc, 2 mA standby, 40 mA alarm Model(s) MMF-302-6A

Six zone interface modules, rating 15-32 V dc, 2 mA standby, 40 mA alarm Model(s) MMF-302-6A

(f13) - Complementary Listed to FSYE, QVAX and SYSW.

(f15) - For use with the Listee's Models ANN-80 and ANN-80-W Remote Annunciators.

(f20) - Complementary Listed under PGWM

NOTE - Intended for use with specific control units as indicated in the control unit installation manual.

[Last Updated](#) on 2018-01-04

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

Copyright © 2018 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2018 Underwriters Laboratories of Canada Inc."